

2019-2022 Information of Ozone Depletion (ODS) Emission

Unit: tons

Annual	2019	2020	2021	2022
R22 refrigerant consumption	2.27	3.71	1.97	1.60
CFC-11 equivalent	0.12	0.20	0.11	0.09

Note 1: Refer to the Ozone Depletion Potential (ODP) coefficient in the Annex of the Montreal Protocol to convert ODS emissions.

Note 2: The ODP value of R22 refrigerant is 0.055 (announced according to the Montreal Protocol), and the ODP value of CFC-11 is 1. The amount of R22 refrigerant used is converted into CFC-11 equivalent (tons), as shown in the information above.