

Concerned Substance emission disclosure indicators

Unit: mg/L

Concerned Substance	Plant Area	Ave. Conc. Emmission	Regulatory Limit
COD	Plant I	13.9	100
	Plant II	94.8	560
	Plant III	175.2	560
	Plant IV	46.9	350
	EVSZ	24.8	500
SS	Plant I	5.2	30
	Plant II	26.1	480
	Plant III	14.0	480
	Plant IV	29.1	200
	EVSZ	40.7	400
Amino-Nitrogen	Plant I	37.7	60
	Plant II	59.4	100
	Plant III	12.3	100
	Plant IV	11.0	70
	EVSZ	13.7	45
Nitrate Nitrogen	Plant I	0.2	50
	Plant II	24.7	50
	Plant III	3.5	50
	Plant IV	5.0	100
	EVSZ	--	-